

# Declaration of Conformity

In Accordance with ANSI/ISEA 125-2014



Alexander Andrew, Inc. 1306 S. Alameda St Compton, CA 90221

Declaration #

A0415029

Declaration Date

4.10.15

Tested Item #

7410

Hinged Roof Anchor

Additional Items Conforming Under this Declaration:

A7410

Alexander Andrew, Inc. declares that the product(s) listed above is in conformity with the requirements of the following performance standard(s):

ANSI Z359.1-2007

Conformity Assessment Method in accordance with ANSI/ISEA 125-2014

Level 1

Level 2

X

Level 3

Level 1: FallTech Lab  
Outside the Scope of  
ISO/IEC Standard 17025:2005

Level 2: FallTech Lab  
Within the Scope of  
ISO/IEC Standard 17025:2005

Level 3: Independent 3rd Party Lab  
accredited to  
ISO/IEC Standard 17025:2005

Supporting  
Documentation

POA05038

Authorized Signature

Name

Dustin Hawkins

Title

VP Business Development

Date

8.19.15

### FallTech Test Report

<b>Test Report Number</b>	POA05038	<b>Date</b>	4/10/2015	<b>Rev</b>		<b>Rev Date</b>	
<b>Report Prepared For</b>	FallTech						
<b>Initiated By</b>	Dan Redden	<b>Test Specification</b>	ANSI Z359.1-2007 4.3.6				
<b>Base Part #</b>	7410	<b>Description</b>	Roof Anchor				
<b>Proposed Part #</b>	N/A	<b>Built By Whom</b>	Production	<b>BOM</b>	No		
<b>Test Request #</b>	Batch Testing	<b>Date Received</b>	4/1/2015	<b>Date Complete</b>	4/9/2015		
<b>Test Operator</b>	Yesbet Sierra	<b>Test Operator</b>	N/A				

#### Material/Sample Identification

Sample ID	Description
WUV	Roof Anchor


#### Test Summary

Test Specification	Test Criteria		Test Result	Pass/Fail
ANSI Z359.1-2007 4.3.6	Static Strength	3,600 Lbf ≥ 1 Minute	5346.5 Lbf	Pass
	Static Strength	Withstand 3,600 Lbf Load Without Cracking, Breaking or Permanent Deformation	No Visible Cracking, Breaking or Permanent Deformation	Pass
	Static Strength	5,000 Lbf ≥ 1 Minute	5318.8 Lbf	Pass

#### Conclusion

FallTech P/N 7410 Roof Anchor meets the requirements of ANSI Z359.1-2007.

#### Report Signatories and Approval

Lab Quality Manager Dan Redden		Date	4/10/2015
Witnessed by	Not Applicable	Date	Not Applicable

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2005. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer to the joint ISO-ILAC-IAF Communique dated January 2009).