

Declaration of Conformity

In Accordance with ANSI/ISEA 125-2014



Alexander Andrew, Inc. 1306 S. Alameda St Compton, CA 90221

Declaration #

A0416036

Declaration Date

4.15.16

Tested Item #

7434S

Permanent 1-D Roof Anchor 8"

Additional Items Conforming Under this Declaration:

Alexander Andrew, Inc. declares that the product(s) listed above is in conformity with the requirements of the following performance standard(s):

ANSI Z359.1-2007

Conformity Assessment Method in accordance with ANSI/ISEA 125-2014

Level 1

Level 2

X

Level 3

Level 1: FallTech Lab
Outside the Scope of
ISO/IEC Standard 17025:2005

Level 2: FallTech Lab
Within the Scope of
ISO/IEC Standard 17025:2005

Level 3: Independent 3rd Party Lab
accredited to
ISO/IEC Standard 17025:2005

Supporting
Documentation

PC-0854

Authorized Signature

Name

Dustin Hawkins

Title

VP Business Development

Date

6.2.16

FallTech Test Report

Test Report Number	PC-0854	Date	4/15/2016	Rev		Rev Date	
Report Prepared For	FallTech						
Initiated By	Dan Redden	Test Specification	ANSI Z359.1-2007 4.3.6				
Base Part #	7434S	Description	Permanent Roof Anchor				
Proposed Part #	N/A	Built By Whom	Production	BOM	No		
Test Request #	PC-0854	Date Received	3/29/2016	Date Complete	4/14/2016		
Test Operator	Yesbet Sierra	Test Operator	Jay Sponholz				

Material/Sample Identification

Sample ID	Description
3213867	Permanent Roof Anchor

Test Summary

Test Specification	Test Criteria	Test Result	Pass/Fail
ANSI Z359.1-2007 4.3.6	Static Strength Parallel 3,600 Lbf. ≥ 1 Minute	3913.1 Lbf.	Pass
	Static Strength Parallel Withstand 3600 lb Load without cracking, breaking or permanent deformation	No Visible Cracking Breaking or Deformation	Pass
	Static Strength Parallel 5000 Lbf. ≥ 1 Minute	5220.7 Lbf.	Pass

Conclusion

FallTech P/N 7434S Permanent Roof Anchor meets the requirements of ANSI Z359.1-2007

Report Signatories and Approval

Lab Quality Manager		Date	4/15/2016
---------------------	---	------	-----------

Witnessed by	Not Required	Date	N / R
--------------	--------------	------	-------

