

Declaration of Conformity

In Accordance with ANSI/ISEA 125-2014 and ANSI/ASSP Z359.7-2019



Alexander Andrew, Inc. 1306 S. Alameda St Compton, CA 90221 (800) 719-4619

Declaration #

A0803080

Declaration Date

8/3/2026

Tested Item #

6160500 /
6161000

Ladder Stanchion Anchor, 5' Length, 5" or 12" Offset
Ladder Stanchion Anchor, 10' Extension for 6160500

Additional Items Conforming Under this Declaration:

Alexander Andrew, Inc. declares that the product(s) listed above is in conformity with the requirements of the following product standard(s):

OSHA 1926.502

Conformity Assessment Method in accordance with ANSI/ISEA 125-2014

Level 1

Level 2

X

Level 3

Level 1: FallTech Lab
Outside the Scope of
ISO/IEC Standard 17025:2017

Level 2: FallTech Lab
Within the Scope of
ISO/IEC Standard 17025:2017

Level 3: Independent 3rd Party Lab
accredited to
ISO/IEC Standard 17025:2017

Supporting
Documentation

PC-3582

Authorized Signature

A handwritten signature in black ink, appearing to read 'Zachary Winters', written over a dashed line.

Name

Zachary Winters

Title

Director of Product and
Applied Engineering

Date

8/3/2026



International Accreditation Service, Inc
3060 Saturn St, Ste 100
Brea, CA 92821 +1 562-364-8201

FallTech Lab - TL-594

ISO/IEC 17025:2017

Alexander Andrew Inc dba FallTech

FallTech Test Report

Test Report No.	PC-3582	Rpt. Date	12/15/2025	Rpt. Rev		Rev Date	
Report Prepared For	FallTech						
Initiated By	Zachary Winters	Test Specification(s)		OSHA 1926.502: (d)(16)(v)			
Part No.	6161000			Part No. Revision		A	
Part Description	Ladder Stanchion Anchor, 10' Extension for 6160500						
Test Request No.	PC-3582			Date Complete		12/11/2025	
Test Operator(s)	Yesbet Sierra / Jay Sponholz						

Material/Sample Identification

Sample ID	Description
DPT 1	Ladder Stanchion Anchor, 10' Extension for 6160500

Test Summary

Test Specification	Test Criteria		Test Result	Pass/Fail
OSHA 1926.502 (d)(15)(V) 360 Lbs. Test Mass 60" Drop Height	Dynamic Strength	Sufficient strength to withstand 3600 Lbf impact energy	3137.8 Lbf.	Pass *

Conclusion

Based upon the samples provided to the Lab: FallTech P/N 6161000 Rev. A meets the requirements of OSHA 1926.502 (d)(15)(v) when tested with 360 lb. mass

Test Exceptions

*Energy absorbing properties inherent to the Ladder Stanchion prevented dynamic force readings equal to or greater than the 3,600 Lbs. as required by the standard
--

Report Signatories and Approval

Lab Quality Manager		Date	12/15/2025
---------------------	---	------	------------