# **S128 MEDICATOR SPECIFICATIONS**

# STENNER PUMPS



- 1 Mounting bracket
- 1 Manual

•

1 Reference poster



#### **SPECIFICATIONS**

Flow Rate Output Control Fixed rate, interfaces with water meter **Reproducibility** ±2% Maximum Working Pressure 60 psi (4.1 bar) Maximum Suction Lift 25 ft (7.6 m) vertical lift, based on water Motor Type Brushless DC motor Shaft rpm (average maximum) 45 Duty Cycle Continuous Maximum Viscosity 1500 Centipoise Motor Voltage (Amp Draw) 120V 60Hz 1PH (0.6) Power Cord Type 120V 60Hz SJTOWA Power Cord Plug End 120V 60Hz 5-15P Power Cord Length 6 ft (1.8 m) Classification Indoor/Outdoor

### MATERIALS OF CONSTRUCTION

All Housings Polycarbonate

Pump Tube Santoprene® (FDA approved)

**Ball Check Valve Components** Ceramic ball (FDA approved); Tantalum spring; FKM seat & O-ring OR

Ceramic ball (FDA approved); Stainless steel spring; EPDM seat; Santoprene® O-ring

Pump Head Rollers and Guide Rollers Polyethylene

Roller Bushings Oil impregnated bronze

Suction/Discharge Tubing Polyethylene (FDA approved)

Tube Fittings, Injection Fittings PVC or Polypropylene (both NSF listed)

Connecting Nuts PVC or Polypropylene (both NSF listed)

Suction Line Strainer and Cap PVC or Polypropylene, (both NSF listed); ceramic weight All Fasteners Stainless steel

Pump Head Thumbscrews Stainless steel; PVC

Pump Head Support and Transition Sleeve Santoprene®

Tube Pull PVC

Leak Detect Components Hastelloy°; Stainless steel NOTE: Refer to the chemical guide for material compatibility. Santoprene® is a registered trademark of Celanese International Corporation. Versilon<sup>®</sup> is a registered trademark of Saint-Gobain Performance Plastics Pellethane\* is a registered trademark of Lubrizol Advanced Materials, Inc. Hastellov® is a registered trademark of Havnes International. Inc.

### **FLOW RATE OUTPUT**

Pump Prefix	Pump Tube	Ounces per Minute	Milliliters per Minute
S4M8X	8X	10.0	295.7
		Approximate outputs @ 50/60Hz	

NOTICE: The information within this chart is solely intended for use as a guide. The output data is an approximation based on pumping water under a controlled testing environment. Many variables can affect the output of the pump. Stenner Pump Company recommends that all metering pumps undergo field calibration by means of analytical testing to confirm their outputs. The information contained in this flyer is not intended for specific application purposes. Stenner Pump Company reserves the right to make changes to prices, products, and specifications at any time without prior notice.

50 West Stoever Ave. • Myerstown, PA 17067 1-800-845-3374 • www.farmerboyag.com