



BATTERY MODULE

- Two Mounting Options:
DIN-Rail or Panel/ Wall Mounting
- IP00 Open Type Protection Level
- Easy Access to the Terminals and the Fuse
- Heavy Duty Fuse Holder and Spare Fuse Included
- UZK12.071 With Installed Battery
- UZO12.07 only Bracket Without Installed Battery

1. GENERAL DESCRIPTION

The UZK12.071 battery module utilizes one non-spillable maintenance-free lead-acid battery that is assembled in one package with all the required wiring included.

The UZK12 battery module is available in two different options. It can be ordered with assembled batteries or as a battery bracket without batteries, allowing for different battery options. The mounting bracket option also allows the batteries to be assembled just in time, avoiding outdated batteries due to limited shelf life.

2. DATA

Battery type	VRLA	Lead-acid
Battery design life	3 to 5 years	acc. EUROBAT
Battery voltage	DC 12V	
Battery capacity	7Ah	
Battery current	max. 30A max. 1.8A	for discharging for charging
Battery fuse	30A	ATO fuse
Temperature sensor	not included	
Charging voltage	13.9V 13.75V 13.6V 13.45V	at 10°C at 20°C at 30°C at 40°C
Self-discharge rate	3%/month	at 20°C
Temperature range	-10°C to +40°C -15°C to +50°C -20°C to +50°C	for charging for discharging for storage
Dimensions	155x124x112mm	WxHxD
Weight	3200g / 7.6lb 550g / 1.21lb	UZK12.071 UZO12.07

3. ORDER NUMBERS

Battery Module	UZK12.071	Battery module with assembled batteries
	UZO12.07	Battery module without assembled batteries
Replacement	UZH12.071	Battery replacement 12V, 7Ah

4. MARKINGS



INDEX

	Page		Page
1. General Description	1	11. Environment	4
2. Data	1	12. Terminals and Wiring.....	5
3. Order Numbers.....	1	13. Protection Features	5
4. Markings.....	1	14. Approvals.....	5
5. Intended Use	2	15. Physical Dimensions and Weight	6
6. Instructions for Disposal of the Battery	2	16. Wall/ Panel Mounting	7
7. Warranty.....	2	17. Recommendations for a Long Battery Life	8
8. Instructions for Battery Storage	3	18. Mounting Orientations	9
9. Installation Instructions	3		
10. Replacing Batteries	4		

The information presented in this document is believed to be accurate and reliable and may change without notice.
No part of this document may be reproduced or utilized in any form without permission in writing from the publisher.

5. INTENDED USE

This module is designed for installation in an enclosure and is intended for the general professional use such as in industrial control, office, communication, and instrumentation equipment.
Do not use this module in equipment, where malfunction may cause severe personal injury or threaten human life.

6. INSTRUCTIONS FOR DISPOSAL OF THE BATTERY

Always dispose the batteries through a recycling organization.
Batteries must be completely discharged before recycling.



7. WARRANTY

3 Year limited warranty except batteries which are considered a service part.

8. INSTRUCTIONS FOR BATTERY STORAGE

- Do not store batteries or battery modules at temperatures higher than 25°C or performance and lifetime might change.
- Do not store discharged batteries. Keep batteries fully charged!
Charge retention is important to get the longest battery life. Stored batteries which are not fully charged age faster then charged batteries.
- Do not store batteries or the battery module longer than nine months without supplementary charging or performance and lifetime might change.
PULS charges every battery before shipment from the factory.
- Recommendation for supplementary charge:
Every 9 months or whenever the open circuit voltage (OCV) falls below 12.6V, the battery module should be charged. Apply a charging voltage of 13.8V (at 25°C) for 72 hours. Batteries with an OCV below 12V must not be charged anymore and must be disposed.

9. INSTALLATION INSTRUCTIONS

This device may only be installed and put into operation by qualified personnel.

For storage, installation and operation, the requirements of the EN 50272-2 as well as other national regulations must be observed.

Place the battery module in a cool area inside a cabinet and ensure sufficient ventilation for the battery. The battery module should be securely mounted on a flat surface or on a DIN-Rail.


If damage or malfunction should occur during installation or operation, immediately turn power off and send unit to the factory for inspection.

The last step is to insert the battery fuse and to store the spare fuse in the designated holes of the plastic cover.

⚠ WARNING Risk of electrical shock, fire, personal injury or death.

- Do not short-circuit the battery poles
- Observe correct battery polarity
- Disconnect battery fuse before working on the battery or on the DC-UPS. Protect against inadvertent re-powering.
- Make sure that the wiring is correct by following all local and national codes.
- Do not modify or repair the unit.
- Do not use in wet locations or in areas where moisture or condensation can be expected.

Fig. 9-1 Wiring scheme




10. REPLACING BATTERIES

Disconnect battery fuse before replacing the battery.

Always dispose the battery through a recycling organization. Batteries must be completely discharged before recycling. Batteries can also be returned to PULS or the battery manufacturer.

Battery replacements can be acquired through PULS. PULS also offers a list with recommended batteries in case batteries need to be acquired elsewhere.

Fig. 10-1 Replacing the battery



To replace battery:

- 1) Loosen screw with only one turn and
- 2) Slide the mounting bracket sideways.
- 3) Tilt the mounting bracket to the front and take it off
- 4) Unplug the battery terminals
- 5) remove the battery
- 6) To insert the new battery use same procedure vice versa.

11. ENVIRONMENT

Operational temperature*)	-10°C**) to +40°C (14°F to 104°F)	for charging
	-15°C to +50°C (5°F to 122°F)	for discharging
Storage temperature	-20°C to +50°C (-4°F to 122°F)	for storage and transportation
Humidity	5 to 95% r.h.	IEC 60068-2-30 Do not energize while condensation is present
Vibration sinusoidal	±4mm at 16.7Hz fixed frequency for 1hour	Vibration in vertical mounting orientation according to IEC/EN 61056-1
Shock	free fall from 20cm onto a wooden floor	Shock with bottom down orientation according to IEC/EN 61056-1
Altitude	0 to 6000m (0 to 20 000ft)	without any restrictions
Degree of pollution	2	IEC 62103, EN 50178, not conductive
LABS compatibility	The unit does not release any silicone or other LABS-critical substances and is suitable for use in paint shops.	

*) Operational temperature is the same as the ambient temperature and is defined as the air temperature 2cm below the unit.

**) Frequently charging below +5°C (41°F) reduced the lifetime of the battery

12. TERMINALS AND WIRING

The terminals are IP20 Finger safe constructed and suitable for field- and factory wiring.

Type	Screw terminals
Solid wire	2.5-4mm ²
Stranded wire	2.5-4mm ²
American Wire Gauge	AWG12-10
Max. wire diameter	3.5mm (including ferrules)
Wire stripping length	7mm / 0.28inch
Screwdriver	3.5mm slotted or cross-head No 2
Recommended tightening torque	0.49Nm, 4.3lb.in



Instructions:

- Use appropriate copper cables that are designed for minimum operating temperatures of:
60°C for ambient up to 45°C and
75°C for ambient up to 60°C minimum
- Follow national installation codes and installation regulations!
- Ensure that all strands of a stranded wire enter the terminal connection!
- Ferrules are allowed.

13. PROTECTION FEATURES

Degree of protection	IP 00	EN/IEC 60529
Class of protection	III	EN/IEC 61140
Internal input fuse	30A	DC-Fuse (ATO blade type)
Isolation voltage between power to chassis	1100Vac	

14. APPROVALS

EC Declaration of Conformity



The CE mark indicates conformance with the low-voltage directive (LVD) 2006/95/EC

Marine



GL (Germanischer Lloyd) classified
Environmental category: A
Marine and offshore applications

15. PHYSICAL DIMENSIONS AND WEIGHT

Width	155mm / 6.1"
Height	124mm / 4.88"
Depth	112mm / 4.41"

for DIN-Rail mounting;

The DIN-rail height must be added to the unit depth to calculate the total required installation depth.

Depth	106mm / 4.17"
Depth	116mm / 4.57"

for wall mounting without DIN-Rail fixture

for bottom mounting with DIN-Rail fixture

Weight	3200g / 7.6lb
	550g / 1.21lb

UZX12.071

UZO12.07

Bracket material	Cover: zinc-plated steel
------------------	--------------------------

Fig. 15-1 Front view




Fig. 15-2 Side view





Fig. 15-3 Isometric view



16. WALL/ PANEL MOUNTING

Panel/ wall mounting is possible by detaching the DIN-Rail brackets

Fig. 16-1 Panel/ wall mounting – Removing the aluminium brackets and plastic slide




Fig. 16-2 Hole pattern for wall mount





Fig. 16-3 Hole pattern for bottom mount




17. RECOMMENDATIONS FOR A LONG BATTERY LIFE

Temperature:

The temperature has the most impact on the service life. The hotter the temperature, the earlier the wear-out phase of the battery begins. The wear-out results in a degradation of battery capacity. Place the battery module in a cool location, E.g. near the bottom of the control cabinet. Do not place the battery module near heat generating devices. Do not overcharge batteries!

Fig. 17-1 **Service life vs. ambient temperature, typ.**




Number of discharge cycles and depth of discharge:

Do not discharge batteries more than necessary. Set buffer time limiter to the required buffer time. The number, as well as the depth of discharging cycles is limited. A replacement of the battery might be necessary earlier.

When choosing the battery capacity, always try to get the next higher capacity than required. The depth of discharge reduces the service life of the battery and limits the number of cycles.


Fig. 17-2 **Battery degradation vs. discharging cycles, typ.**



18. MOUNTING ORIENTATIONS


The standard mounting orientation is the vertical installation onto a flat surface.

Fig. 18-1 **Standard mounting orientation**



The following mounting orientations are also allowed:

Fig. 18-2 **Allowed mounting orientation**



Do not use the battery module in an upside down position:

Fig. 18-3 **Forbidden mounting orientation**

