



Regulatory Fire & Safety Signage

Regina, Saskatchewan

Fire Routes

- Said that they have no specifics on hand because each property will have different requirements based on where it is in the city
- Follows the general requirements under the National Building Code of Canada 2015, 3.2.5 provisions for firefighting (access routes)
 - https://www.nrc-cnrc.gc.ca/eng/publications/codes_centre/2015_national_building_code.html
(\$70 for 3 month access)

No Parking

Traffic Bylaw 9900

<http://open.regina.ca/dataset/6dc81ae7-cea8-40bf-a458-0e5aee0a7477/resource/0b653133-4de6-4b87-9212-bd4a32fe0224/download/9900.pdf>

- No parking is allowed where signs depict “no stopping” or “no parking”
- See general information under [Other](#), Permanent Signs

Traffic Engineering

- No requirements for signage to be enforceable
- They strictly follow the Manual of Uniform Traffic Control Devices Canada (MUTCDC)



Safety Media

Fire & Life Safety Essentials

www.safetymedia.com

sales@safetymedia.com

1-800-420-9737

No Smoking

Smoking Bylaw

<http://open.regina.ca/dataset/73d6e326-61fc-4beb-92da-2a34174b207e/resource/0c790ec2-7e4d-4fc8-ab91-4d5b47345b82/download/gprojectsopen-data-publishedpublished-to-open-databylawsbylaw-no.-2017-20-the-smoking-bylaw-2017.pdf>

Signs for owners of outdoor public places must

- Be at least 12.7cm x 12.7cm in size
- Include in black or red on a white background, the international symbol designating no smoking, with the symbol having a diameter of at least 9 cm
- Include the words: "Smoking and Vaping Prohibited" or "No Smoking or Vaping", or other similar wording, in black on a white background
- Be clearly visible

Business Signage:

<https://www.regina.ca/opencms/export/sites/regina.ca/residents/bylaw/.media/pdf/busines-signage.pdf>



**NO SMOKING
NO VAPING**

Bylaw #2017-20



Safety Media

Fire & Life Safety Essentials

www.safetymedia.com

sales@safetymedia.com

1-800-420-9737

Business Stickers

https://www.regina.ca/opencms/export/sites/regina.ca/residents/bylaw/.media/pdf/no-smoking_vaping-stickers.pdf



**Thank you for not
smoking or vaping
within **10 metres** of
doorways, windows
and air intakes.**

As required by The Smoking Bylaw 2017-20

Towing

See general information under [Other](#), Permanent Signs

No Dumping

See general information under [Other](#)

Underground Parking

Bylaw Enforcement Officer, 3067777000

Exit signs follow the National Fire Code/Building Code

Building Code

http://www.tnb.ca/en/brands/lumacell/files/3LU_Building_Code_EN.pdf

Every exit sign shall:

- Be visible on approach to the exit



Safety Media

Fire & Life Safety Essentials

www.safetymedia.com

sales@safetymedia.com

1-800-420-9737

- Consist of a green pictogram and a white or lightly tinted graphical symbol meeting the colour specifications referred to in ISO 3864-1, "Graphical symbols – Safety colours and safety signs – Part 1: Design principles for safety signs in workplaces and public areas,"
- Conform to the dimensions indicated in ISO 7010, "Graphical symbols – Safety colours and safety signs – for the following symbols (see A-3.4.5.1. (2)(c))
 - i) E001 emergency exit left,
 - ii) E002 emergency exit right,
 - iii) E005 90-degree directional arrow, and
 - iv) E006 45-degree directional arrow.

Internally illuminated exit signs shall be continuously illuminated and:

- Where illumination of the sign is powered by an electrical circuit, be constructed in conformance with CSA C22.2 No. 141, "Emergency Lighting Equipment," or
- Where illumination of the sign is not powered by an electrical circuit, be constructed in conformance with CAN/ULC-S572, "Photoluminescent and Self-Luminous Signs and Path Marking Systems."

Externally illuminated exit signs shall:

- Be continuously illuminated and be constructed in conformance with CAN/ULC-S572, "Photoluminescent and Self-Luminous Signs and Path Marking Systems." (See A-3.4.5.1. (4))
- The circuitry serving lighting for externally and internally illuminated exit signs shall a) serve no equipment other than emergency equipment, and b) be connected to an emergency power supply as described in Sentences 9.9.12.3.(2), (3) and (7).

Where no exit is visible from a public corridor, from a corridor used by the public, or from principal routes serving an open floor area having an occupant load of more than 150:

- An exit sign conforming to Clauses (2)(b) and (c) with an arrow or pointer indicating the direction of egress shall be provided

Fire Safety Plan Box Provisions

Fire Prevention, 306-777-7000

- Have no specific requirements in a bylaw, etc.



Accessibility Guidelines

UBASR

<http://www.qp.gov.sk.ca/documents/English/Regulations/Regulations/U1-2R5.pdf>

- Governed by Saskatchewan's Uniform Building and Accessibility Standards Regulations
- No mention of sign requirements
- Follows the National Building Code of 1995 (\$)

Other?

Requirements for signs under the building bylaw

<http://open.regina.ca/dataset/2effca07-38fd-47a2-819b-1e3609b95bdd/resource/fe78d8c5-bb10-491a-b4c6-35700bd2bec5/download/2003-7c11-3.pdf>

- Signs and any supporting structure must be fastened with non-corrosive fasteners or have fastening devices protected from corrosion

Ground signs

- Noncombustible material (unless sign does not exceed 5m above the surface of the ground)
 - Signs 7.6m maximum above the ground are constructed with non-combustible columns and braces and supports, and may have the display area including backing of combustible materials
- Foundation exceeding 5m in height must be made of concrete

Wall signs

- Noncombustible materials when they exceed 4m², are located more than 7.6m above grade, or are located within 0.6m of any window, fire escape, or exit above the second storey floor line

Trespassing Signs

<http://www.publications.gov.sk.ca/freelaw/documents/English/Statutes/Statutes/T20-2.pdf>

Signs must

- Name the activity and has an oblique line drawn through the name of the activity or,
- Shows a graphic representation of that activity and has an oblique line drawn through it



Safety Media

Fire & Life Safety Essentials

www.safetymedia.com

sales@safetymedia.com

1-800-420-9737

Permanent Sign Guidelines

<https://www.regina.ca/opencms/export/sites/regina.ca/residents/city-planning/.media/pdf/permanent-sign-guide.pdf>

Directional sign - states safety or warning messages, traffic/parking directions, other instructions/directions/orders for people making use of the land

- May be erected without a permit in any zone if it does not exceed 0.9 square meters in area

Disclaimer: *The material and information contained on this document is for general information purposes only. Please contact your local authorities before making any business, legal or other decision.*