



Regulatory Fire & Safety Signage

Saskatoon, Saskatchewan

Fire Routes

<https://www.saskatoon.ca/sites/default/files/documents/city-clerk/bylaws/7200.pdf>

- Regulated under Bylaw #7200: Traffic Bylaw
- Signs must indicate "fire lane"

No Parking

Permanent Sign Guidelines

<https://www.regina.ca/opencms/export/sites/regina.ca/residents/city-planning/.media/pdf/permanent-sign-guide.pdf>

Without permit

- Does not exceed 0.9m² in area
 - If larger than this, a permit is required, and requirements will be specified on the application

**Clarifying Information from bylaw office

- A Directional Sign is any sign stating only safety or warning messages, traffic and/or parking directions or other instructions, directions or orders to persons making use of the premises.

No Smoking

The Tobacco Control Regulations

<http://www.publications.gov.sk.ca/freelaw/documents/english/Regulations/Regulations/t14-1r1.pdf>



Safety Media

Fire & Life Safety Essentials

www.safetymedia.com

sales@safetymedia.com

1-800-420-9737

No Smoking

- At least 12.7cm x 12.7cm
- Contain the international no smoking symbol, that is at least 9cm in diameter

Signs for Schools

Posted at main or secondary entrances:

- 22.5cm x 30cm
- Must contain the words "Our school and grounds are tobacco free at all times"

Posted on the door at each entrance:

- Must be 15cm x 20cm
- Must contain the words "Our school and grounds are tobacco free at all times"



Towing

Permanent Sign Guidelines

See information under [No Parking](#)



No Dumping

Permanent Sign Guidelines

See information under [No Parking](#)

Underground Parking

The Fire and Protection Services Bylaw

<https://www.saskatoon.ca/sites/default/files/documents/city-clerk/bylaws/7990.pdf>

- Must post signs to indicate the prohibitions of vehicles, fueled or using propane in any manner, in conspicuous locations near the principal entrances of the parking facility
 - Lettering not less than 100mm high with a 15mm stroke

Building Code

http://www.tnb.ca/en/brands/lumacell/files/3LU_Building_Code_EN.pdf

Every exit sign shall:

- Be visible on approach to the exit
- Consist of a green pictogram and a white or lightly tinted graphical symbol meeting the colour specifications referred to in ISO 3864-1, "Graphical symbols – Safety colours and safety signs – Part 1: Design principles for safety signs in workplaces and public areas,"
- Conform to the dimensions indicated in ISO 7010, "Graphical symbols – Safety colours and safety signs – for the following symbols (see A-3.4.5.1. (2)(c))
 - i) E001 emergency exit left,
 - ii) E002 emergency exit right,
 - iii) E005 90-degree directional arrow, and
 - iv) E006 45-degree directional arrow.

Internally illuminated exit signs shall be continuously illuminated and:

- Where illumination of the sign is powered by an electrical circuit, be constructed in conformance with CSA C22.2 No. 141, "Emergency Lighting Equipment," or
- Where illumination of the sign is not powered by an electrical circuit, be constructed in conformance with CAN/ULC-S572, "Photoluminescent and Self-Luminous Signs and Path Marking Systems."

Externally illuminated exit signs shall:



Safety Media

Fire & Life Safety Essentials

www.safetymedia.com
sales@safetymedia.com
1-800-420-9737

- Be continuously illuminated and be constructed in conformance with CAN/ULC-S572, "Photoluminescent and Self-Luminous Signs and Path Marking Systems." (See A-3.4.5.1. (4))
- The circuitry serving lighting for externally and internally illuminated exit signs shall a) serve no equipment other than emergency equipment, and b) be connected to an emergency power supply as described in Sentences 9.9.12.3.(2), (3) and (7).

Where no exit is visible from a public corridor, from a corridor used by the public, or from principal routes serving an open floor area having an occupant load of more than 150:

- An exit sign conforming to Clauses (2)(b) and (c) with an arrow or pointer indicating the direction of egress shall be provided

Fire Safety Plan Box

Fire Department Administrative Office
3069752520

- Have never heard of this before

Accessibility Guidelines

UBASR

<http://www.qp.gov.sk.ca/documents/English/Regulations/Regulations/U1-2R5.pdf>

- Governed by Saskatchewan's Uniform Building and Accessibility Standards Regulations
- No mention of sign requirements
- Follows the National Building Code of 1995 (\$)

Other?

Fire Safety Plan Outline

<https://www.saskatoon.ca/sites/default/files/documents/fire-department/FireSafetyPlan.pdf>



For buildings with a single stage fire alarm system and no elevators:

IN CASE OF FIRE
UPON DISCOVERY OF FIRE
<ul style="list-style-type: none">• Leave the Fire area immediately• Close and latch all doors behind you• Activate the fire alarm pull station to notify building occupants• Leave the building immediately via the nearest exit• Telephone the Saskatoon Fire and Protective Services - DIAL 9-1-1
UPON HEARING FIRE ALARM
<ul style="list-style-type: none">• LEAVE the BUILDING immediately via nearest exit• Take your keys• CLOSE and latch DOORS behind you – do not lock
IF YOU ENCOUNTER HEAVY SMOKE
<ul style="list-style-type: none">• STAY in your suite IF you are UNABLE TO EXIT• DIAL 9-1-1 and await further instructions
REMAIN CALM
WARNING
Tampering with any fire protection systems and equipment is a criminal offence subject to a heavy fine, imprisonment or both. ISSUED BY THE FIRE CHIEF



For buildings with a single stage fire alarm system and elevators:

<p style="text-align: center;">IN CASE OF FIRE</p>
<p style="text-align: center;">UPON DISCOVERY OF FIRE</p>
<ul style="list-style-type: none">• Leave the Fire area immediately• Close and latch all doors behind you• Activate the fire alarm pull station to notify building occupants• Leave the building immediately via the nearest exit or stairwell exit• Telephone the Saskatoon Fire and Protective Services – DIAL 9-1-1
<p style="text-align: center;">DO NOT USE ELEVATORS</p>
<p style="text-align: center;">UPON HEARING FIRE ALARM</p>
<ul style="list-style-type: none">• LEAVE the BUILDING immediately via nearest exit or stairwell exit• Take your keys• CLOSE and latch DOORS behind you – do not lock
<p style="text-align: center;">IF YOU ENCOUNTER HEAVY SMOKE</p>
<ul style="list-style-type: none">• Return to or stay in your suite or office if you are unable to leave by an alternate exit• DIAL 9-1-1 and await further instructions
<p style="text-align: center;">REMAIN CALM</p>
<p style="text-align: center;">WARNING</p>
<p style="text-align: center;">Tampering with any fire protection systems and equipment is a criminal offence subject to a heavy fine, imprisonment or both. ISSUED BY THE FIRE CHIEF</p>



For buildings with a two-stage fire alarm system:

IN CASE OF FIRE
UPON DISCOVERY OF FIRE
<ul style="list-style-type: none">• Leave the Fire area immediately• Close and latch all doors behind you• Activate the fire alarm pull station to notify building occupants• Leave the building immediately via the nearest exit or stairwell exit• Telephone the Saskatoon Fire and Protective Services – DIAL 9-1-1
DO NOT USE ELEVATORS
UPON HEARING FIRE ALARM
INTERMITTENT SIGNAL- <ul style="list-style-type: none">• Stand by and prepare to leave the building IF CONTINUOUS SIGNAL- <ul style="list-style-type: none">• LEAVE the BUILDING immediately via nearest exit or stairwell exit• Take your keys• CLOSE and latch DOORS behind you – do not lock
IF YOU ENCOUNTER HEAVY SMOKE
<ul style="list-style-type: none">• Return to or stay in your suite or office if you are unable to leave by an alternate exit.• DIAL 9-1-1 and await further instructions
REMAIN CALM
WARNING
Tampering with any fire protection systems and equipment is a criminal offence subject to a heavy fine, imprisonment or both. ISSUED BY THE FIRE CHIEF

Disclaimer: The material and information contained on this document is for general information purposes only. Please contact your local authorities before making any business, legal or other decision.